



**Washington State
Department of Transportation**
Paula J. Hammond, P.E.
Secretary of Transportation

Southwest Region
11018 Northeast 51st Circle
P.O. Box 1709
Vancouver, WA 98668-1709
360-905-2000 / Fax 360-905-2222
TTY: 1-800-833-6388
www.wsdot.wa.gov

March 1, 2011

American Construction Co., Inc.
1501 Taylor Way
Tacoma, WA 98421-4100

Contract 8078, I-5, Columbia River Bridge
Temporary Pile Test Program
WA 0.3 to OR MP 308.0
State Project
Serial Letter No. 22

RE: Response to Request for Information No. 8 – reusable crates

Gentlemen:

On February 28, 2011, we received Request for Information No. 8 which asked the following question.

Do we need to turn in shop drawings of the wooden crates for the Unconfined bubble rings, and the manifold/controls? Can we just build it?

Submittal of shop drawings will not be required for the two crates to be provided for storage of the bubble curtain equipment. As specified on page 100 of the Contract Special Provisions, the two reusable crates shall be water tight with bottom vents as they will be stored in an open yard and both crates shall have provisions for moving and lifting by forklifts.

If there are any questions, please contact this office at (360) 816-2208.

Sincerely,

Frank Green, P.E.
CRC Structures Engineering Manager

KAD:np

cc: Document Control
M. Degenhart
N. Peppers