



**Washington State
Department of Transportation**

Paula J. Hammond, P.E.
Secretary of Transportation

Southwest Region
11018 Northeast 51st Circle
P.O. Box 1709
Vancouver, WA 98668-1709
360-905-2000 / Fax 360-905-2222
TTY: 1-800-833-6388
www.wsdot.wa.gov

March 2, 2011

American Construction Co., Inc.
1501 Taylor Way
Tacoma, WA 98421-4100

Contract 8078, I-5, Columbia River Bridge
Temporary Pile Test Program
WA 0.3 to OR MP 308.0
State Project
Serial Letter No. 24

RE: Response to Request for Information #7

Gentlemen:

On February 25, 2011, we received Request for Information No. 7 which asked the following questions.

- *Please provide details on how you want the Bubble Curtain Manifold painted.*
- *What color? Coating thickness?*
- *What is the pre-painting treatment (surface cleaning/prep) requirements?*
- *We're only painting the manifold, correct?*

You are correct that the Bubble Curtain Manifold is the only item to be painted. The top coat of the three-coat paint system shall be Washington Gray and meet the requirements of Sections 6-07.3(9)B and 9-08.1(8) of the Standard Specifications. For answers to the remaining questions above please refer to Section 6-07 of the Standard Specifications.

If there are any questions, please contact this office at (360) 816-2208.

Sincerely,

Frank Green, P.E.
CRC Structures Engineering Manager

KAD:np

cc: Document Control
M. Degenhart
N. Peppers