

From: [Daly, Keith](#)
To: [document.control;](#)
cc: [Peppers, Nicki;](#)
Subject: Contract 8078, Correspondence to Contractor
Date: Thursday, March 03, 2011 4:13:02 PM
Attachments: [RE_ Contract 8078 - RFI 005_ Painting specifications for the Bubble Curtain Manifold.pdf](#)

Please file attached document under contract 8078, correspondence to the contractor.

Thanks,

Keith

From: [Daly, Keith](#)
To: ["vernonu@americanconstco.com"](mailto:vernonu@americanconstco.com)
Cc: [Green, Frank](#)
Subject: RE: Contract 8078 - RFI 005: Painting specifications for the Bubble Curtain Manifold
Date: Thursday, March 03, 2011 4:09:51 PM
Attachments: [Emailing_421-012-RequesttoSubletWork.pdf.msg](#)

Vernon,

As stated in serial letter #24 the manifold for bubble curtain shall be painted Washington Gray. Please refer to Sections 6-07.3(9)B, 9-08.1(8), and 9-08.3 of the Standard Specifications.

Please submit a Request to Sublet Work (Form #421-012) for Coatings Unlimited Inc. which must be approved prior to starting this work. I have attached a copy of this form for your use. If you have any questions please let me know.

Thanks,

Keith Daly
Budget Manager

[Columbia River Crossing Project](#) | <mailto:dalyk@columbiarivercrossing.org>
700 Washington St. Suite 300, Vancouver, WA 98660
office: 360.816.8870 | Office: 503.256.2726 Ext. 8870
Fax: 360.737.0294

From: Vernon Uy [<mailto:vernonu@americanconstco.com>]
Sent: Thursday, March 03, 2011 2:51 PM
To: Daly, Keith
Subject: RE: Contract 8078 - RFI 005: Painting specifications for the Bubble Curtain Manifold

Hi Keith.

Please provide information on the color. We talked about "WSDOT green" for a color. Our painting sub states there are different shades/tones of WSDOT green. Can you provide me with a color number?

Attached is the RAM Form for our painting sub, Coatings Unlimited Inc. of Kent, WA. Coatings Unlimited Inc. will sandblast and paint per WSDOT Specification 6-07.3(9)

Thanks.

Vernon Uy
American Construction Company, Inc.
(425) 870-3217

From: "Daly, Keith" <dalyk@columbiarivercrossing.com>
Sent: Wednesday, March 02, 2011 10:12 AM
To: vernonu@americanconstco.com

Subject: RE: Contract 8078 - RFI 005: Painting specifications for the Bubble Curtain Manifold

Vernon,

You are correct Section 6-07.3(9) Painting New Steel Structures in the Standard Specifications is the section we discussed yesterday. Please submit the required documents in accordance with this section. Prior to performing any painting all required documentation will need to be approved. Please remember to coordinate the painting work with Mark Degenhart so any required inspection can be done.

Thanks,

Keith Daly
Budget Manager

[Columbia River Crossing Project ? mailto:dalyk@columbiarivercrossing.org](mailto:dalyk@columbiarivercrossing.org)
700 Washington St. Suite 300, Vancouver, WA 98660
office: 360.816.8870 ? Office: 503.256.2726 Ext. 8870
Fax: 360.737.0294

From: Vernon Uy [mailto:vernonu@americanconstco.com]
Sent: Wednesday, March 02, 2011 9:49 AM
To: Daly, Keith
Subject: fw: Contract 8078 - RFI 005: Painting specifications for the Bubble Curtain Manifold

Hi Keith.

Based on our phone conversation yesterday, and after review of the WSDOT specs (Painting Section 6-07), I think the painting requirements detailed on Section 6-07.3(9) Painting New Steel Structures will suffice. These are on pages 6-156 thru 6-158 of the specs.

Please concur. Once I receive an agreement, I will turn in the required submittals.

Thanks.

Vernon Uy
American Construction Company, Inc.
(425) 870-3217

From: "Vernon Uy" <vernonu@americanconstco.com>
Sent: Friday, February 25, 2011 12:09 PM
To: "Keith Daly - WSDOT" <dalyk@columbiarivercrossing.org>
Subject: Contract 8078 - RFI 005: Painting specifications for the Bubble Curtain Manifold

Hi Keith.

Now is the time to look into the painting requirements on the Bubble Curtain Manifold. Sheet ND4, Note 1 states to "paint steel components per standard specifications."

Questions:

Please provide details on how you want the Bubble Curtain Manifold painted.

- What color? Coating thickness?
- What is the pre-painting treatment (surface cleaning/prep) requirements?
- We're only painting the manifold, correct?

Let me know. Thanks.

Vernon Uy
American Construction Company, Inc.
(425) 870-3217

*** eSafe scanned this email for malicious content ***

*** IMPORTANT: Do not open attachments from unrecognized senders ***