

From: [Green, Frank](#)
To: [Daly, Keith](#);
cc: [Degenhart, Mark](#); [Peppers, Nicki](#);
Subject: FW: Contract 8078 - RFI 004: Swapping Pile Location Question
Date: Monday, February 07, 2011 8:21:04 AM

Keith,

Swapping pile locations as they have proposed is acceptable. We just need to ensure good "as-built" location data.

From: Vernon Uy [mailto:vernonu@americanconstco.com]
Sent: Sunday, February 06, 2011 7:44 PM
To: Green, Frank; Degenhart, Mark
Cc: Daly, Keith
Subject: Contract 8078 - RFI 004: Swapping Pile Location Question

Hi Frank, Mark.

Plan Sheet PLS1 shows pile locations for temporary piles A-1, A-2,... B-1 and B-2.

Question: Is it possible to "swap" locations of the 24" and 48" piles? Can the locations for A-1 and A-2 (24" piles) be switched for the locations of A-3 and A-4 (48" piles), respectively? Can the location of B-1 (24" pile) be switched for B-2 (48" pile), respectively?

Let me know. Thanks.

Vernon Uy
American Construction Company, Inc.
(425) 870-3217